GOVERNMENT OF ANDHRA PRADESH

ABSTRACT

Water Resources Department – Permission to M/s RA Chem Pharma Limited, R.S.No.50/1, Mukteswarapuram(V), Jaggaiahpeta Mandal, Krishna District for drawl of 500KL/day(0.2044 Cusecs) or 0.0064 TMC per annum of surplus water during the flood time from Krishna River for a period of Five(5) years for their industrial purpose– Accorded – Orders – Issued.

WATER RESOURCES (REFORMS) DEPARTMENT

G.O.MS.No. 59 Dated: 16-07-2019

Read the following:-

1. From the Chief Engineer, Krishna Delta System, Vijayawada Lr.No.CE/KDS/VJA/OT-3/AE-10/F-IW/840, dated:15.03.2019.
2. From the Chief Engineer, Krishna Delta System, Vijayawada Lr.No.CE/KDS/VJA/OT-3/AE-10/F-IW/1584, dated:28.05.2019.

O R D E R:

In the reference 1st read above, the Chief Engineer, Krishna Delta System, Vijayawada has stated that the firm M/s. RA Chem Pharma Limited, has filed an application dated:22.02.2019 in the Department of Industries Website, requesting for permission for drawl of 500 KL/day of water from River Krishna at Mukteswarapuram Village in Krishna District from Water Resources Department and the same was communicated by the Engineer- in-Chief(Irrigation) vide letter dated:27.02.2019 and requested to take necessary action as per the instructions issued by the Government vide G.O.Ms.No.202, Industries & Commerce Department and Govt. Memo. No. 2772/Reforms/A2/2015-1, Water Resources Department,Dated: 30.09.2015. Further stated that the Executive Engineer, K.C.Division, Vijayawada vide letter dated: 13.03. 2019 has submitted a report on the issue.

2. In the reference 2nd read above, the Chief Engineer, Krishna Delta System, Vijayawada has stated that, the Superintending Engineer, Irrigation circle, Vijayawada has also submitted a report on the issue. The Chief Engineer, Krishna Delta System, Vijayawada has therefore requested the Government to accord permission in favour of M/s. RA Chem Pharma Limited, Mukteswarapuram(V), Jaggaiahpeta Mandal, Krishna District for drawl of 500KLD (0.2044 Cusecs) or 0.0064 TMC per annum of surplus water during the flood time from Krishna River for a period of Five (5) years with the following conditions:

(1) The annual requirement of 0.0064 TMC of water per annum from the Krishna River during flood seasons only, keeping in view the meager water requirement.

(2) The water drawn from the river should be utilized for the purpose for which permission is granted. Any misuse in this regard will entail cancellation of the permission without any notice and liable for imposition of penalty.

(3) The entire cost of infrastructure to draw water shall be borne by the industry only.

(4) Water meters or suitable approved measuring devices should be installed by the industry at their own cost to measure the water consumed and water measuring devices should be kept under the control of Water Resources Department and the representatives of the user shall be present at all times for taking readings.

(PTO)

(5) The industry should pay water rate at the existing rates and subject to revision by the Government from time to time. In case of failure to pay water rate, royalty, the permission to draw Water shall stands cancelled.

(6) No field bodhi or pipeline shall be taken through or along with Government land without approval of Government and if permission is accorded by the Government the lease of Government land should be paid as fixed by the Government only.

(7) The industry should obtain the prior concurrence of concerned Department for laying pipeline and for crossing etc.

(8) The industry should make their own arrangements for supplementation of water in their premises only.

(9) The industry should make their own arrangements to dispose the treated effluents as per norms of Andhra Pradesh Pollution Control Board in their premises only and should obtain prior permission if any needed from Government to dispose treated effluents in the natural resources.

(10)The Water Resources Department reserves the right for cancellation of the permission without assigning any reasons thereof.

(11)The Water Resources Department is no way responsible of non-supply /non availability of water due to any reasons in any particular water year.

(12) The industry must strengthen the canal / river margin 100 Mts or as decided by the Water Resources Department on either side of the proposed off take point to avoid slips, erosion of banks and to protect existing margins as directed by the Department.

(13)The industry should lay the pipeline duly leaving not less than 1.00 Mts., from the toe of the flood bank.

(14)The industry has to construct CC walls to avoid leakages at pipeline crossings.

(15)The industry should follow the Revenue Board Standing orders (B.S.O.).

(16)The industry should pay security deposit at 2.5% on 10 years water charges for which permission is granted.

(17)The permission accorded shall be initially for a period of 5 years only. The permission shall have to be renewed well in advance before the expiry of the permission.

(18)The industry shall pay one year water charges as advance and amounts due to the Department before entering into agreement.

(19)The industry should make its own arrangements creating storage facilities for the requirement of water 0.0103 TMC during the flood period.

(20)The present rate of royalty charges as per the Government Memo No.2772/Reforms/A2/2015-1, dated:30.09.2015 is Rs.5.50 per 1000 gallons for consumptive use. The water royalty charges are likely to be revised by the Government from time to time and the industry shall pay the revised rates as fixed by the Government from time to time.

(21)The firm has to pay the water charges for the estimated quantity in advance at the start of the Finance Year (i.e.) before 10th April every year as per BSO.

(Continued…p.3)

(22)The consumptive utilization of 0.0064 TMC of annual requirement as required should not be exceeded under any circumstances.

(23)A detailed plan showing the location, the intake arrangements, conveyance system etc., shall be furnished to the Department.

(24)The industry shall abide any other conditions laid down by the Government/ Department from time to time.

(25)The permission does not confer any riparian right to the industry.

(26)Non adherence of any of the conditions by the industry entails cancellation of the permission without any notice.

(27) The concurrence of the District Collector, Krishna for the proposals has to be obtained before drawing the water and taken up the work.

(28)In addition to the above, the following conditions may also be kept in view:-

(i) The quantity of water to be actually permitted for the drawal shall be as certified by the Industries Department.

(ii) The industry shall obtain all the necessary clearances required.

(iii)Water storage facility with a minimum capacity of 0.0032 TMC within the premises of the unit shall be constructed to the satisfaction of the Water Resources Department before the industry is granted the permission to utilize the water.

(iv)The point of drawal of water shall be kept above the FRL / normal flood level.

(v) The pump house shall be constructed at the point of drawal and Water Resources Department shall carry out regular inspections to curb any unauthorized drawal of water during the non-monsoon period.

(vi)The department will be responsible for positioning appropriate and fool proof safe guards ensuring that under no circumstances shall the industry draw water during the non-flood season.

(vii)Willful and proven unauthorized tapping of water in non-flood season or in excess of the quantity authorized, in violation of the conditions under which the permission is granted, shall besides the cancellation of the permission granted, invite penal action, as per the law of land.

3. In view of the circumstances explained by the Chief Engineer, Krishna Delta System, Vijayawada, Government after careful examination of the matter hereby accord permission to M/s. RA Chem Pharma Limted, R.S.No.50/1, Mukteswarapuram(V), Jaggaiahpeta Mandal, Krishna District for drawl of 500KL/day (0.2044 Cusecs) or 0.0064 TMC per annum of surplus water during the flood time from Krishna River near Mukteswarapuram in Krishna District for a period of Five (5) years for their industrial purpose subject to the terms and conditions mentioned at para two (2) above and subject to the concurrence of District Collector and the Pollution Control Board and also payment of water charges @ Rs.5.50/-per 1000 gallons as per the Govt. Memo.No.2772/Reforms/A2/2015-1,Water Resources Department, dt: 30.09.2015.

(PTO)

4. The Engineer-in-Chief (Irrigation), Water Resources Department, Andhra Pradesh, Vijayawada and the Collector & District Magistrate of Krishna District shall take necessary action accordingly.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

ADITYANATH DAS
SPECIAL CHIEF SECRETARY TO GOVERNMENT

To
The Engineer-in-Chief(Irrigation), Water Resources Department,
Andhra Pradesh, Vijayawada.
The Collector & District Magistrate, Krishna District.
The Managing Director, Pollution Control Board, Andhra Pradesh,Vijayawada.
M/s. RA Chem Pharma Limted, R.S.No.50/1, Mukteswarapuram(V),
Jaggaiahpeta Mandal, Krishna District
Copy to:
The Chief Engineer, Krishna Delta System, Vijayawada.
The Superintending Engineer, Irrigation Circle, Vijayawada.
The Private Secretary to Special Chief Secretary to Government, Water Resources Department.
The Private Secretary to Hon'ble Minister, Water Resources Department.
SF/SC

//FORWARDED::BY ORDER//

SECTION OFFICER.